

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50705989 0001

Berichtsnummer Report No.:

CN25067K 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

EN IEC 60947-5-1:2025

EN IEC 60947-1:2021

Geräteidentifikation
Product Identification
Produkt:

Auxiliary Contacts

Product:

(Auxiliary Contact)

Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Technische Daten auf nächste(r) Seite(n) gelistet

Technical Data:

Technical Data is listed on the next page(s)

Gültig ab:

2025-12-16

Valid from:
Zertifizierungsstelle:
Certification body:
Ausstellungsdatum:

2025-12-16

Date of issue:

Yongming Yang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50705989 0001

Berichtsnummer *Report No.:*

CN25067K 001

Produkt *Product:* Auxiliary Contacts
(Auxiliary Contact)**Modell** *Type:* **Bezeichnung** *Designation:*
F4-a b, F3-a b, F1-a b

a may be 0,1,2,3,4

b may be 0,1,2,3,4

"a" denotes the number of normally-open contacts

"b" denotes the number of normally-closed contacts

Trademark : (Tengen(Logo))

Ui : 690V

Uimp : 8kV

Ith : 10A

IP : 20

AC-15: Ue: AC380V Ie:0.95A

DC-13: Ue: DC220V Ie:0.15A

Conditional short-circuit current: 1kA

ANLAGE (Appendix): 1.0

