

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50702612 0001

Berichtsnummer Report No.:

CN25EJ31 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

EN IEC 60947-4-1:2025

EN IEC 60947-1:2021

Geräteidentifikation
Product Identification
Produkt:

AC contactor

Product:

(AC Contactor)

Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Technische Daten auf nächste(r) Seite(n) gelistet

Technical Data:

Technical Data is listed on the next page(s)

Gültig ab:

2025-11-27

Valid from:
Zertifizierungsstelle:

Certification body:

Ausstellungsdatum:

2025-11-27

Date of issue:

Yongming Yang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com
TÜVRheinland®
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50702612 0001

Berichtsnummer *Report No.:*

CN25EJ31 001

Produkt *Product:* AC contactor
(AC Contactor)

Modell *Type:* **Bezeichnung** *Designation:*
CJX2-115, CJX2-150, CJX2-170, CJX2-150C, CJX2-200C, CJX2-250C

Trademark : (Tengen(Logo))

Rated Operational Voltage Current under Utilization Category:

 CJX2-115
 AC-1:
 Ue:AC220V, AC380V, AC660V
 Ie:200A
 AC-3:
 Ue:AC220V, Ie:115A
 Ue:AC380V, Ie:115A
 Ue:AC660V, Ie:86A

 CJX2-150
 AC-1:
 Ue:AC220V, AC380V, AC660V
 Ie:200A
 AC-3:
 Ue:AC220V, Ie:150A
 Ue:AC380V, Ie:150A
 Ue:AC660V, Ie:107A

 CJX2-170
 AC-1:
 Ue:AC220V, AC380V, AC660V
 Ie:200A
 AC-3:
 Ue:AC220V, Ie:170A
 Ue:AC380V, Ie:170A
 Ue:AC660V, Ie:118A

 CJX2-150C
 AC-1:
 Ue:AC220V, AC380V, AC690V, 1140V
 Ie:150A

 CJX2-200C
 AC-1:
 Ue:AC220V, AC380V, AC690V, 1140V
 Ie:200A

 CJX2-250C
 AC-1:
 Ue:AC220V, AC380V, AC690V, 1140V
 Ie:250A


Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50702612 0001

Berichtsnummer *Report No.:*

CN25EJ31 001

Produkt *Product:* AC contactor
(AC Contactor)

Modell *Type:* **Bezeichnung** *Designation:*

CJX2-115, CJX2-150, CJX2-170, CJX2-150C, CJX2-200C, CJX2-250C

Number of Poles : 3 Poles

Conventional Free Air

Thermal Current (Ith) : 200A(CJX2-115, CJX2-150, CJX2-170, CJX2-200C)
150A(CJX2-150C), 250A(CJX2-250C)

Impulse Withstand Voltage: 8.0kV

Rated Insulation Voltage : 1140V

Co-ordination Type : Type 2

Conditional Short-circuit

Current(Iq) : 50kA

Pollution Degree : 3

IP Code : IP20(CJX2-115, CJX2-150, CJX2-170)
IP00(CJX2-150C, CJX2-200C, CJX2-250C)

Control Circuit

Us : AC24V, 36V, 48V, 110V/120V, 220V/230V, 380V/400V

ANLAGE (Appendix): 1.0

