



Ref. Certif. No.

CN76045

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor

Name and address of the applicant

ZHEJIANG TENGEN ELECTRIC CO.,LTD.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

ZHEJIANG TENGEN ELECTRIC CO.,LTD.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang Tengen Smart Electrics Co.,Ltd.

Note: When more than one factory, please report on page 2

No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

N/A

Customer's Testing Facility (CTF) Stage used

TGCA-40004,TGCA-50004,TGCA-65004,TGCA-80004,TGC A-95004

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020; IEC 60947-4-1:2023

A sample of the product was tested and found to be in conformity with

(2025)MJDQ-CB1467

As shown in the Test Report Ref. No. which forms part of this Certificate

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jan.22,2026

Signature: 
Xie ZhaoXu





Ref. Certif. No.

CN76045

TGCA-40004, TGCA-50004, TGCA-65004, TGCA-80004, TGCA-95004

Ui: 1000V; Uimp: 8kV;

Ue: AC220V/240V, AC380V/440V, AC500V/550V, AC660V/690V;

Ith=60A (TGCA-40004), 80A (TGCA-50004), 100A (TGCA-65004), 110A (TGCA-80004), 135A (TGCA-95004);

TGCA-40004:

AC-1: Ue/le: AC220V/240V/60A, AC380V/440V/60A, AC500V/550V/60A, AC660V/690V/60A;

AC-3: Ue/le: AC220V/240V/40A, AC380V/440V/40A, AC500V/550V/34A, AC660V/690V/34A;

AC-3e: Ue/le: AC220V/240V/40A, AC380V/440V/40A, AC500V/550V/34A, AC660V/690V/34A;

AC-4: Ue/le: AC220V/240V/18.5A, AC380V/440V/18.5A, AC500V/550V/9A, AC660V/690V/9A;

TGCA-50004:

AC-1: Ue/le: AC220V/240V/80A, AC380V/440V/80A, AC500V/550V/80A, AC660V/690V/80A;

AC-3: Ue/le: AC220V/240V/50A, AC380V/440V/50A, AC500V/550V/39A, AC660V/690V/39A;

AC-3e: Ue/le: AC220V/240V/50A, AC380V/440V/50A, AC500V/550V/39A, AC660V/690V/39A;

AC-4: Ue/le: AC220V/240V/24A, AC380V/440V/24A, AC500V/550V/12A, AC660V/690V/12A;

TGCA-65004:

AC-1: Ue/le: AC220V/240V/100A, AC380V/440V/100A, AC500V/550V/100A, AC660V/690V/100A;

AC-3: Ue/le: AC220V/240V/65A, AC380V/440V/65A, AC500V/550V/42A, AC660V/690V/42A;

AC-3e: Ue/le: AC220V/240V/65A, AC380V/440V/65A, AC500V/550V/42A, AC660V/690V/42A;

AC-4: Ue/le: AC220V/240V/28A, AC380V/440V/28A, AC500V/550V/14A, AC660V/690V/14A;

TGCA-80004:

AC-1: Ue/le: AC220V/240V/110A, AC380V/440V/110A, AC500V/550V/110A, AC660V/690V/110A;

AC-3: Ue/le: AC220V/240V/80A, AC380V/440V/80A, AC500V/550V/49A, AC660V/690V/49A;

AC-3e: Ue/le: AC220V/240V/80A, AC380V/440V/80A, AC500V/550V/49A, AC660V/690V/49A;

AC-4: Ue/le: AC220V/240V/37A, AC380V/440V/37A, AC500V/550V/17.3A, AC660V/690V/17.3A;

TGCA-95004:

AC-1: Ue/le: AC220V/240V/135A, AC380V/440V/135A, AC500V/550V/135A, AC660V/690V/135A;

AC-3: Ue/le: AC220V/240V/95A, AC380V/440V/95A, AC500V/550V/49A, AC660V/690V/49A;

AC-3e: Ue/le: AC220V/240V/95A, AC380V/440V/95A, AC500V/550V/49A, AC660V/690V/49A;

AC-4: Ue/le: AC220V/240V/44A, AC380V/440V/44A, AC500V/550V/21.3A, AC660V/690V/21.3A;

Us: AC24V, 36V, 48V, 110V, 120V, 220V, 240V, 380V, 400V, 415V, 440V, 50Hz/60Hz;

Degree of protection of enclosure: IP20 (Front side); Number of poles: 4P; 50Hz/60Hz

Page 1 of 1

Additional information (if necessary)

Date:

Jan.22,2026

Signature:

謝肇煦
Xie ZhaoXu