



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Certificate No.: CE260314010029

Product Moulded Case Circuit Breaker

Applicant ZHEJIANG TENGEN ELECTRIC CO.,LTD.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model TGBD-125

Ui:690V;Uimp:4kV; Ue:AC220/230/240V(1P),
AC380/400/415V(2P,3P,4P); In:63A,80A,100A,125A;

Technical data Ics:6kA;lcu:6kA; Type of release:thermo-magnetic;
CAT:A; Pole:1P,2P,3P,4P(All the poles are protective poles); 50/60Hz;Suitable for isolation

This is to certify that, on the basis of the tests undertaken as per Report No. C-14201-DC2600452, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Feb.04,2026

Valid until: Feb.03,2029

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

謝肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE