



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240303008870

Product

Plastic case circuit breaker

Applicant

ZHEJIANG TENGGEN ELECTRIC CO.,LTD.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGM1-800L, TGM1-800M, TGMNR-800L,
TGMNR-800M, TGM1BX-800L, TGM1BX-800M

Technical data

See attachment

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2025CQC0303-016407, the submitted sample(s) of the above item complies
with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jan.19,2026

Valid until: May.12,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE240303008870

TGM1-800L, TGM1-800M, TGMNR-800L, TGMNR-800M, TGM1BX-800L, TGM1BX-800M;

Ui: 800V;

Uimp: 8kV;

Ue: AC400/415V, AC660/690V;

In: 630A、700A、800A;

Over-current release: Thermo-magnetic;

Ics:

Type L: 35kA/AC400/415V, 15kA/AC660/690V

Type M: 37.5kA/AC400/415V, 15kA/AC660/690V

Icu:

Type L: 50kA/AC400/415V, 30kA/AC660/690V

Type M: 75kA/AC400/415V, 30kA/AC660/690V

Selectivity category: A;

Poles: 3P, 3P+N (3 protected poles with an uninterrupted neutral pole), 4P (3 protected poles with a switched neutral pole), 4P;

Applicable for isolation (except 3P+N);

Trip class: 10;

Auxiliary contact, alarm contact: 2NO2NC;

Ith: 3A;

AC-15: Ue/Ie: AC380V/0.4A;

DC-13: Ue/Ie: DC220V/0.15A;

Accessories with electronic circuits:

Motor-operator: CD3-800/M: Us: AC220/AC230V, AC380V/AC400V;

Undervoltage release: 800QT: Us: AC220V, AC380V;



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE